



# Energy Wheel Operation

55 to 90% **total** (sensible + latent) effectiveness




# Technology Comparison



	Heat Pipe	Sensible Plate	Membrane Core	Mem.@ 450 FPM	Heat Wheel
MBHTotal	57.4	59	95.2	104.7	207.6
EffectivenessTotal	19.8	20.4	32.9	36.1	71.7
RERTotal	33.03	35.75	24.14	37.58	119.10

# RTU Integrated ERV


- Cost effective method of providing a RTU with an ERV
- Retro-fit or factory install
- Optional economizer and power exhaust function



# RTU Combination Curb



# Why Correct Humidity Is Important




# Humidity Buildup at Part Load

Load Condition	Design Load Sunny Day	Part-Load Condition
Occupancy	100%	20%
Outdoor Air Condition	95 db, 76 wb	80 db, 71 wb
Supply Air Cfm Cooling Coil Dewpoint	15,000 53.5°F	15,000 65.5°F
Room Conditions	75 db <b>48% rh</b>	75 db <b>71% rh</b>

# Reduced Operating Range

- Range of ventilation air conditions introduced to the HVAC unit is significantly reduced
- HVAC unit cooling system can be downsized and will operate at a higher sensible heat ratio (less dehumidification required), which is typical of most packaged DX rooftop units
- HVAC unit heating system can be downsized or possibly even eliminated

## “Weather Compressor”



# IECC 2012: Requirement for Energy Recovery


Required in many high population areas (gyms, theaters, etc.)

Check map for climate zone

Look up supply fan CFM and OA fraction

Note: IECC 2006 and 2009 only required ERVs above 70% OA on a 5,000 supply CFM system (regardless of climate)

**C403.2.6 Energy recovery ventilation systems.** Where the supply airflow rate of a fan system exceeds the values specified in Table C403.2.6, the system shall include an energy recovery system. The energy recovery system shall have the capability to provide a change in the enthalpy of the outdoor air supply of not less than 50 percent of the difference between the outdoor air and return air enthalpies, at design conditions. Where an air economizer is required, the energy recovery system shall include a bypass or controls which permit operation of the economizer as required by Section C403.4








TABLE C403.2.6  
ENERGY RECOVERY REQUIREMENT

CLIMATE ZONE	PERCENT (%) OUTDOOR AIR AT FULL DESIGN AIRFLOW RATE					
	≥ 30% and < 40%	≥ 40% and < 50%	≥ 50% and < 60%	≥ 60% and < 70%	≥ 70% and < 80%	≥ 80%
	DESIGN SUPPLY FAN AIRFLOW RATE (cfm)					
3B, 3C, 4B, 4C, 5B	NR	NR	NR	NR	≥ 5000	≥ 5000
1B, 2B, 5C	NR	NR	≥ 26000	≥ 12000	≥ 5000	≥ 4000
6B	≥ 11000	≥ 5500	≥ 4500	≥ 3500	≥ 2500	≥ 1500
1A, 2A, 3A, 4A, 5A, 6A	≥ 5500	≥ 4500	≥ 3500	≥ 2000	≥ 1000	> 0
7, 8	≥ 2500	≥ 1000	> 0	> 0	> 0	> 0

**Exception:** An energy recovery ventilation system shall not be required in any of the following conditions:

1. Where energy recovery systems are prohibited by the *International Mechanical Code*.
2. Laboratory fume hood systems that include at least one of the following features:
  - 2.1. Variable-air-volume hood exhaust and room supply systems capable of reducing exhaust and makeup air volume to 50 percent or less of design values.
  - 2.2. Direct makeup (auxiliary) air supply equal to at least 75 percent of the exhaust rate, heated no warmer than 2°F (1.1°C) above room setpoint, cooled to no cooler than 3°F (1.7°C) below room setpoint, no humidification added, and no simultaneous heating and cooling used for dehumidification control.
3. Systems serving spaces that are heated to less than 60°F (15.5°C) and are not cooled.
4. Where more than 60 percent of the outdoor heating energy is provided from site-recovered or site solar energy.
5. Heating energy recovery in Climate Zones 1 and 2.
6. Cooling energy recovery in Climate Zones 3C, 4C, 5B, 5C, 6B, 7 and 8.
7. Systems requiring dehumidification that employ energy recovery in series with the cooling coil.
8. Where the largest source of air exhausted at a single location at the building exterior is less than 75 percent of the design *outdoor air* flow rate.
9. Systems expected to operate less than 20 hours per week at the *outdoor air* percentage covered by Table C403.2.6

<u>OUTSIDE ERV MODEL</u>		<u>VENTILATION LOAD</u>		<u>NEW O/A CONDITIONS</u>		<u>ECONOMIC ANALYSIS</u>		
<u>AIR</u>		<u>A/C REDUCTION</u>	<u>HEAT REDUCTION</u>	<u>SUMMER</u>	<u>WINTER</u>	<u>PAYBACK</u>	<u>ROI</u>	<u>ANNUAL</u>
<u>(CFM)</u>		<u>(TONS)</u>	<u>(BTU/h)</u>	<u>(DB / WB)</u>	<u>(DB / WB)</u>	<u>(YEARS)</u>	<u>%</u>	<u>SAVINGS</u>
500	EVAA bolt-on	1.0	31,367	82.2 / 68.7	41.0 / 33.8			\$400
500	EVCC	1.4	43,961	78.4 / 65.7	56.1 / 44.6	4.6	22	\$550
1000	EVCD	2.6	80,611	79.7 / 66.4	50.4 / 41.2	3.1	32	\$940
1500	EVDD	3.9	120,367	79.8 / 66.5	49.9 / 40.9	1.6	63	\$1,400
2000	EVED	5.3	163,748	79.5 / 66.3	50.9 / 41.6	1.6	63	\$1,940
2500	EVED	6.2	194,161	80.3 / 66.8	47.6 / 39.3	1.1	91	\$2,100
3000	EVHF	7.9	245,774	79.4 / 66.4	51.5 / 41.7	1.1	91	\$3,270
4000	EVHD	10.8	331,501	79.4 / 66.2	51.7 / 42.1	0.6	157	\$4,160
5000	EVKG	13.3	409,900	79.5 / 66.3	51.1 / 41.7	0.6	167	\$5,550
6000	EVLD	16.5	505,827	79.1 / 66.0	53.0 / 42.9	0.9	111	\$6,570
7000	EVKD	18.0	554,912	80.0 / 66.6	49.0 / 40.3	0.4	250	\$6,570
8000	EVLD	20.6	635,832	79.9 / 66.6	49.1 / 40.4	0.3	333	\$7,580
9000	EVND	24.8	755,867	79.2 / 66.0	52.6 / 42.8	0.4	250	\$9,750
10000	EVMD	25.4	783,645	80.1 / 66.8	48.2 / 39.8	0.4	250	\$9,150
12,000	EVND	31.0	943,255	80.2 / 66.6	48.0 / 40.0	0.1	1000	\$11,100
14,000	EVRD	36.9	1,121,163	79.9 / 66.4	49.3 / 40.8	0.5	200	\$13,600
16,000	EVSD	42.6	1,295,721	79.7 / 66.3	50.0 / 41.3	0.4	250	\$16,000
18,000	EVSD	46.5	1,414,388	80.2 / 66.6	48.0 / 40.0	0.3	333	\$16,700
20,000	EVTD	51.4	1,560,067	80.3 / 66.6	47.5 / 39.7	0.1	1000	\$18,300

Project Name: Fitness Gym

4/10/2009

**MicroMetl Corporation AIRX ERC DESIGN POINT ANALYSIS**

<u>DESIGN CONDITIONS</u>	<u>Dry Bulb, F</u>	<u>Wet Bulb, F</u>	<u>Enthalpy, Btu/lb</u>
SUMMER, Outdoor	95.00	75.00	38.80
SUMMER, Indoor	75.00	63.00	28.74
WINTER, Outdoor	-10.00	-10.00	-1.90
WINTER, Indoor	72.00	54.00	22.71

<b>Project Unit:</b> ERV-5	<b>Model Number:</b> EVDD	
SUPPLY AIR FLOW RATE, cfm	1440	1440
EXHAUST AIR FLOW RATE, cfm	1440	1440
Latent Effectiveness	70.47%	70.78%
Sensible Effectiveness	76.26%	76.68%
Measured Effectiveness (S/W)	73.7%	75.7%

<b>SUPPLY AIR CONDITIONS</b>	<b>Summer</b>	<b>Winter</b>
Dry Bulb Temperature, F	79.68	51.64
Wet Bulb Temperature, F	66.44	41.88
Enthalpy, Btu/lb	31.38	16.23
Relative Humidity, %	50.5	42.9

<b>DESIGN LOADS, Btu/h</b>	<b>Summer</b>	<b>Winter</b>
Outside Air, Sensible	29,620	129,055
Outside Air, Latent	32,431	32,330
Outside Air, Total	62,051	161,385

<b>RECOVERED LOADS, Btu/h</b>	<b>Summer</b>	<b>Winter</b>
Sensible Recovered	22,588	90,015
Latent Recovered	22,945	21,752
Total Recovered	45,532	111,767

<b>Net OA Load</b>	16,519	42,164
--------------------	--------	--------

**INSTALLED HVAC REDUCTION**

COOLING, Tons	3.79	
HEATING, Btu/h		119,220



Project Name: Fitness Gym

4/10/2009

MicroMetl Corporation AIRX ERC SystemEER ANALYSIS

Airxchange Component

Unitary Equipment



Model	ERV RER	Unitary Name	Unitary Capacity	Unitary EER	ERV Cap. (Y) %	SystemEER
EVDD						
1 : ERV-5	64.66	48HJE012	120000.0	11.0	28	14.25

Project Name:

Fitness Gym

4/10/2009

MicroMetl Corporation AIRX ERC ECONOMIC SUMMARY

Model	Supply cfm	Exhaust cfm	Coolg Saved MBtu	Cooling \$ Saved	Heatg Saved MBtu	Heating \$ Saved	Fan kWh Used	Fan \$ Spent	Net \$ Savings
EVEF									
1 : ERV-1	2280	2500	26,633	511	370,306	4,747	9,179	797	4,461
EVEF									
2 : ERV-2	2280	2500	26,633	511	370,306	4,747	9,179	797	4,461
EVDD									
3 : ERV-4	1320	1320	17,574	337	238,252	3,054	4,550	395	2,996
EVDD									
4 : ERV-5	1440	1440	18,784	361	255,372	3,274	5,292	460	3,175
EVAA									
5 : ERV-6	430	400	4,503	86	64,796	831	1,088	95	823
EVDD									
6 : ERV-8	1440	1440	18,784	361	255,372	3,274	5,292	460	3,175
EVAA									
7 : ERV-9	240	240	3,167	61	43,649	560	475	41	579
EVEF									
8 : ERV-10	1720	1720	21,436	411	296,576	3,802	5,006	435	3,778
EVEF									
9 : ERV-11	2300	2300	26,130	501	363,351	4,658	8,534	741	4,418
EVCC									
10 : ERV-3	550	600	7,832	150	107,044	1,373	1,995	173	1,350
EVCC									
11 : ERV-7	730	730	9,597	184	131,458	1,686	2,833	246	1,624
SUMMARY									
All Units	14730	15190	181,072	3,474	2,496,482	32,005	53,425	4,640	30,839



1 **Fitness Gym**  
 2 **Net Present Value — [ERV]**  
 3 **4/10/2009**


**Simple Payback = 2.1 years**

Capital & Operational Costs	Value
ERV Cost	\$ 54,000
ERV Combo Curb Cost	\$ 23,000
Original RTU Curb Cost	\$ 10,000
RTU Cost Savings	\$ 2,500
Additional Install Labor	\$ 1,000
Annual Maintenance	\$ 500
Expected Annual Inflation	2.5%
Annual Energy Savings	\$ 30,800
Expected Annual Energy Increase	5.0%
Discount Rate	4.0%

End user cost  
 End user cost  
 End user cost, this backs out original curb cost because you now have combo curbs instead  
 End user cost, how much are they saving by purchasing the smaller RTUs  
 End user cost, this is just the extra cost to install the ERVs and should not include any regular RTU install costs  
 Today's dollars, regular filter changes, annual wheel cleaning, general inspection  
 US averaged 2.6% for past 15 years (1992 to 2007)  
 Today's dollars  
 Use best guess for average increase over next 15 years (good luck!) - 2008 industry predications of 15-40% for natural gas, EIA/DOE says NG and LP pretty flat in 2009, EIA/DOE estimates electric to increase 2.3% in 2009 and 2.0% in 2010  
 Discount Rate is the rate you could get if this money was invested elsewhere

Gray cells will be calculated for you and do not require any entry.

Term in years	Expenses			Income Energy Costs	Cash flow	Cumulative Cash Flow
	Annual Costs	Other Costs	Total			
0	\$ 65,500		\$ 65,500		\$ (65,500)	\$ (65,500)
1	\$ 500	\$ 1	\$ 501	\$ 30,800	\$ 30,299	\$ (35,201)
2	\$ 513	\$ 1	\$ 514	\$ 32,340	\$ 31,827	\$ (3,375)
3	\$ 525	\$ 1	\$ 526	\$ 33,957	\$ 33,431	\$ 30,056
4	\$ 538	\$ 1	\$ 539	\$ 35,655	\$ 35,115	\$ 65,172
5	\$ 552	\$ 1	\$ 553	\$ 37,438	\$ 36,885	\$ 102,056
6	\$ 566	\$ 1	\$ 567	\$ 39,309	\$ 38,743	\$ 140,799
7	\$ 580	\$ 1	\$ 581	\$ 41,275	\$ 40,694	\$ 181,493
8	\$ 594	\$ 1	\$ 595	\$ 43,339	\$ 42,743	\$ 224,236
9	\$ 609	\$ 1	\$ 610	\$ 45,506	\$ 44,895	\$ 269,132
10	\$ 624	\$ 1	\$ 625	\$ 47,781	\$ 47,155	\$ 316,287
11	\$ 640	\$ 1	\$ 641	\$ 50,170	\$ 49,529	\$ 365,816
12	\$ 656	\$ 1	\$ 657	\$ 52,678	\$ 52,021	\$ 417,838
13	\$ 672	\$ 1	\$ 673	\$ 55,312	\$ 54,639	\$ 472,477
14	\$ 689	\$ 1	\$ 690	\$ 58,078	\$ 57,388	\$ 529,864
15	\$ 706	\$ 1	\$ 707	\$ 60,982	\$ 60,274	\$ 590,139
				<b>NPV =</b>	<b>\$ 403,375</b>	
				<b>IRR =</b>	<b>51%</b>	



# Example Rebates for ERVs

- Minnesota Power
  - \$0.75 per CFM
- Focus on Energy in Wisconsin
  - \$0.75 per CFM
- Minnesota Xcel
  - \$1.00 per CFM
- Peoples Gas and North Shore Gas in Illinois
  - \$0.75 per CFM
- All other Midwestern utilities use custom rebate programs

Please read all rules and qualifications for each incentive.



**Staged Air Volume (SAV)**

**...or Single Zone VAV**

**...or Multi-stage Air Volume (MSAV)**

**...or Adaptive Fan Control**

# SAV™ System Overview

**Standard and High Efficiency units**

**Electro-mechanical or Digital Controls**

**VFD: pre-configured and adjustable**

★ **Adaptive Integrated Economizer Control:**



**Prevents over/under ventilation**

Industry Acronym	Definition	Application Need
VAV	Variable Air Volume	Typically multi-zone, large applied systems
<b>SAV</b>	<b>Staged Air Volume</b>	Single zone VAV, simple, saves energy!
CAV	Constant Air Volume	Traditional System


(VFD)  
Speed Controller

Fan Automatically Adjusts To Unit Operation Per New Standard

Indoor Fan Motor  
Belt Drive 2 Speed



# Why Two Speed Fan Control?



# SAV™ SYSTEM DESIGN

## Why a VFD?

- A two speed (two winding) indoor fan motor would require the next size motor frame in order to achieve the same CFM. The VFD system can use the smaller standard motor frame.
- VFDs can also provide advanced options for special application including soft start capabilities, higher power factors, and lower full load KVA values
- VFDs also allow programming to meet very specific applications, and to adjust the speed of the powered motor.

# Variable Frequency Drives (VFDs)



- Retro-fit to fans
- Varies the power input to motor
- On average building fan systems in the US are oversized by 60%\*
- If a motor running at 100% speed costs \$1,000/month, what about:
  - Running at 75% speed = \$420
  - Running at 50% speed = \$125
  - Due to the Affinity Laws
- Soft start means less wear & tear on couplings, belts, and motors
- Payback less than 18 months

# FAN LAW BASICS

## Energy saved...

Let's quickly re-visit the third fan law:

Brake horsepower (BHP) varies as the cube of the fan speed:


$$\frac{BHP_1}{BHP_2} = \left[ \frac{RPM_1}{RPM_2} \right]^3$$

For simplicity, if we assume  $RPM_1 = 1000$ ,  $BHP_1 = 2.0$ , and then decrease fan speed to 677 RPM (or 67%)

$$BHP_2 = BHP_1 \left[ \frac{RPM_2}{RPM_1} \right]^3$$


$$BHP_2 = 2.0 \left[ \frac{677}{1000} \right]^3$$

$$BHP_2 \approx .62$$



**33% speed decrease,  
delivers  
69% energy savings!**

# Staged Air Volume (SAV)



- Improves humidity control and saves energy
- Saves about 25-30% electrical energy in Midwest climate
- Minimum OA needs means of automatic adjustment when fan slows
- Similar logic could potentially be applied to heating mode if RTU has multiple stage heat, but pay attention to heat exchanger airflow needs

# ASHRAE 90.1-2010 Fan Power Limitation

## 6.4.3.10 Single Zone Variable-Air-Volume Controls.


HVAC systems shall have variable airflow controls as follows:

- b. Effective January 1, 2012, all air-conditioning equipment and air-handling units with direct expansion cooling and a cooling capacity at AHRI conditions greater than or equal to 110,000 Btu/h that serve single zones shall have their supply fans controlled by two-speed motors or variable-speed drives. At cooling demands less than or equal to 50%, the supply fan controls shall be able to reduce the airflow to no greater than the larger of the following:
  1. Two-thirds of the full fan speed, or
  2. The volume of outdoor air required to meet the ventilation requirements of Standard 62.1.

- All manufacturers offer (or will) SAV on 10 ton RTUs and up...several offer on smaller sizes also
- Note: this is a requirement of ASHRAE 90.1-2010 and 2013, but is not currently included in IECC 2012 (probable for IECC 2015 when published)



# Example Manufacture Product Offering w/ SAV Option




Models only available with SAV

Values are averaged

# Operating Cooling Cost Comparison

## Annual Operating Costs\*\*



**Savings between  
27% to 56% - WOW!**

Annual Energy Savings (\$, %) In  
Using High Efficiency RTUs\*


	10 Ton	15 Ton	20 Ton
Mid Tier w/ SAV	\$ 359 39%	\$ 320 27%	\$ 523 35%
Mid Tier	\$ 596 51%	\$ 655 43%	\$ 842 46%
Entry Level w/ SAV	\$ 454 45%	\$ 558 39%	\$ 834 46%
Entry Level	\$ 709 56%	\$ 916 51%	\$ 1,217 55%

\* These models use three stages of cooling capacity control and matching fan speed controls

### \*\*Building Profile:

Memphis, TN (Single Story Office Building  
Simulated 10, 15 and 20 ton Models  
Using DOE Energy Plus software  
.10 kWh

# Operating Cooling Cost Comparison



\* Annual estimated electric energy savings utilizing Carrier's Hourly Analysis (HAP) Program v4.6. Based on cooling and ventilation fan runtime hours using ASHRAE 90.1 office application, default schedule, weather and building data. Carrier model 48/50TC 12 at .10 (\$/kWh) energy rate.

# Chicago Cooling Cost Comparison

## Job Information

Job Title:

Job Type:

Notes:

## Location Information

Region:

Location:

City:

## Building Information

Building Type:

Unit Peak Clg Load:  Tons

## Energy Prices

Input Data:

Electric Price (Avg):  \$/kWh

Gas Price (Avg):  \$/MCF

## Equipment Information

	Baseline	Proposed
Unit Description:	<input type="text" value="Unit 1"/>	<input type="text" value="Unit 2"/>
Equipment Type:	<input type="text" value="Cooling with Gas Heat"/>	<input type="text" value="Cooling with Gas Heat"/>
Model:	<input type="text" value="48TC"/>	<input type="text" value="48TC"/>
Size:	<input type="text" value="ED12 (Medium Heat)"/>	<input type="text" value="ED12 (Medium Heat)"/>
Refrigerant:	<input type="text" value="R-410a"/>	<input type="text" value="R-410a"/>
Age (yrs):	<input type="text" value="0"/> Years	<input type="text"/>
Nominal Cooling Capacity:	<input type="text" value="10.0"/> Tons	<input type="text" value="10.0"/> Tons
AHRI Cooling Rating:	<input type="text" value="11.10"/> <input type="text" value="EER"/>	<input type="text" value="11.10"/> <input type="text" value="EER"/>
Capacity Control:	<input type="text" value="2-Stage"/>	<input type="text" value="2-Stage"/>
Heating Capacity:	<input type="text" value="184.0"/> MBH	<input type="text" value="184.0"/> MBH
AHRI Heating Rating:	<input type="text"/>	<input type="text"/>
Heating Efficiency:	<input type="text" value="82"/> %	<input type="text" value="82"/> %
Indoor Fan Power:	<input type="text" value="Med. Static, 3Pt"/> <input type="text" value="3.70"/> BHP	<input type="text" value="Med. Static, 3Pt"/> <input type="text" value="3.70"/> BHP
Indoor Fan Control:	<input type="text" value="1-Speed"/>	<input type="text" value="2-Speed"/>
Economizer:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Energy Recovery:	<input type="checkbox"/>	<input type="checkbox"/>
DCV (CO2) Control:	<input type="checkbox"/>	<input type="checkbox"/>
Purchase Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Installation Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Ann. Maint. + Repair (\$/yr):	<input type="text" value="0"/>	<input type="text" value="0"/>
Downtime Loss (\$/yr.)	<input type="text" value="0"/>	<input type="text"/>

# Chicago Cooling Cost Comparison

## Job Information

Job Title: Illinois Example

Job Type: Replacement

Notes:

## Key Results

Energy Cost Savings over 5 years:	\$2,885
Maintenance, Repair, Downtime, Refrig. Savings over 5 years:	\$0
Total Savings over 5 years:	\$2,885
Annual Energy Cost Savings:	\$577 (30%)

## Energy Cost Savings

Criteria	Unit 1 (\$)	Unit 2 (\$)	Energy Savings (\$)	Percent Savings (%)
Indoor Fan	\$1,379	\$752	\$627	45%
Cooling Electric	\$268	\$256	\$13	5%
Heating Electric	na	na	na	na
Heating Natural Gas	\$275	\$337	\$-62	na
<b>Annual Energy Costs</b>	<b>\$1,922</b>	<b>\$1,345</b>	<b>\$577</b>	<b>30%</b>

# Madison Cooling Cost Comparison

## Job Information

Job Title:

Job Type:

Notes:

## Location Information

Region:

Location:

City:

## Building Information

Building Type:

Unit Peak Clg Load:  Tons

## Energy Prices

Input Data:

Electric Price (Avg):  \$/kWh

Gas Price (Avg):  \$/MCF

## Equipment Information

	Baseline	Proposed
Unit Description:	Unit 1	Unit 2
Equipment Type:	Cooling with Gas Heat	Cooling with Gas Heat
Model:	48TC	48TC
Size:	ED12 (Medium Heat)	ED12 (Medium Heat)
Refrigerant:	R-410a	R-410a
Age (yrs):	<input type="text" value="0"/> Years	<input type="text"/>
Nominal Cooling Capacity:	<input type="text" value="10.0"/> Tons	<input type="text" value="10.0"/> Tons
AHRI Cooling Rating:	<input type="text" value="11.10"/> <input type="text" value="EER"/>	<input type="text" value="11.10"/> <input type="text" value="EER"/>
Capacity Control:	2-Stage	2-Stage
Heating Capacity:	<input type="text" value="184.0"/> MBH	<input type="text" value="184.0"/> MBH
AHRI Heating Rating:	<input type="text"/> <input type="text" value="COP"/>	<input type="text"/> <input type="text" value="COP"/>
Heating Efficiency:	<input type="text" value="82"/> %	<input type="text" value="82"/> %
Indoor Fan Power:	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP
Indoor Fan Control:	1-Speed	2-Speed
Economizer:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Energy Recovery:	<input type="checkbox"/>	<input type="checkbox"/>
DCV (CO2) Control:	<input type="checkbox"/>	<input type="checkbox"/>
Purchase Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Installation Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Ann. Maint. + Repair (\$/yr):	<input type="text" value="0"/>	<input type="text" value="0"/>
Downtime Loss (\$/yr.):	<input type="text" value="0"/>	<input type="text"/>

# Madison Cooling Cost Comparison

**Job Title:** Madison Example

**Job Type:** Replacement

**Notes:**

## Key Results

<b>Energy Cost Savings over 5 years:</b>	<b>\$3,395</b>
<b>Maintenance, Repair, Downtime, Refrig. Savings over 5 years:</b>	<b>\$0</b>
<b>Total Savings over 5 years:</b>	<b>\$3,395</b>
<b>Annual Energy Cost Savings:</b>	<b>\$679 (29%)</b>

## Energy Cost Savings

Criteria	Unit 1 (\$)	Unit 2 (\$)	Energy Savings (\$)	Percent Savings (%)
Indoor Fan	\$1,665	\$927	\$739	44%
Cooling Electric	\$277	\$268	\$9	3%
Heating Electric	na	na	na	na
Heating Natural Gas	\$382	\$451	\$-69	na
<b>Annual Energy Costs</b>	<b>\$2,325</b>	<b>\$1,646</b>	<b>\$679</b>	<b>29%</b>

# Eau Claire Cooling Cost Comparison

**Job Information**

Job Title:

Job Type:

Notes:

**Location Information**

Region:

Location:

City:

**Building Information**

Building Type:

Unit Peak Clg Load:  Tons

**Energy Prices**

Input Data:

Electric Price (Avg):  \$/kWh

Gas Price (Avg):  \$/MCF

Equipment Information	Baseline	Proposed
Unit Description:	<input type="text" value="Unit 1"/>	<input type="text" value="Unit 2"/>
Equipment Type:	<input type="text" value="Cooling with Gas Heat"/>	<input type="text" value="Cooling with Gas Heat"/>
Model:	<input type="text" value="48TC"/>	<input type="text" value="48TC"/>
Size:	<input type="text" value="ED12 (Medium Heat)"/>	<input type="text" value="ED12 (Medium Heat)"/>
Refrigerant:	<input type="text" value="R-410a"/>	<input type="text" value="R-410a"/>
Age (yrs):	<input type="text" value="0"/> Years	<input type="text"/>
Nominal Cooling Capacity:	<input type="text" value="10.0"/> Tons	<input type="text" value="10.0"/> Tons
AHRI Cooling Rating:	<input type="text" value="11.10"/> <input type="text" value="EER"/>	<input type="text" value="11.10"/> <input type="text" value="EER"/>
Capacity Control:	<input type="text" value="2-Stage"/>	<input type="text" value="2-Stage"/>
Heating Capacity:	<input type="text" value="184.0"/> MBH	<input type="text" value="184.0"/> MBH
AHRI Heating Rating:	<input type="text"/> <input type="text" value="COP"/>	<input type="text"/> <input type="text" value="COP"/>
Heating Efficiency:	<input type="text" value="82"/> %	<input type="text" value="82"/> %
Indoor Fan Power:	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP
Indoor Fan Control:	<input type="text" value="1-Speed"/>	<input type="text" value="2-Speed"/>
Economizer:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Energy Recovery:	<input type="checkbox"/>	<input type="checkbox"/>
DCV (CO2) Control:	<input type="checkbox"/>	<input type="checkbox"/>
Purchase Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Installation Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Ann. Maint. + Repair (\$/yr):	<input type="text" value="0"/>	<input type="text" value="0"/>
Downtime Loss (\$/yr.):	<input type="text" value="0"/>	<input type="text"/>



# Eau Claire Cooling Cost Comparison

**Job Title:** Eau Claire Example

**Job Type:** Replacement

**Notes:**

## Key Results

<b>Energy Cost Savings over 5 years:</b>	<b>\$3,064</b>
<b>Maintenance, Repair, Downtime, Refrig. Savings over 5 years:</b>	<b>\$0</b>
<b>Total Savings over 5 years:</b>	<b>\$3,064</b>
<b>Annual Energy Cost Savings:</b>	<b>\$613 (24%)</b>

## Energy Cost Savings

<b>Criteria</b>	<b>Unit 1 (\$)</b>	<b>Unit 2 (\$)</b>	<b>Energy Savings (\$)</b>	<b>Percent Savings (%)</b>
Indoor Fan	\$1,670	\$989	\$681	41%
Cooling Electric	\$280	\$274	\$6	2%
Heating Electric	na	na	na	na
Heating Natural Gas	\$611	\$684	\$-74	na
<b>Annual Energy Costs</b>	<b>\$2,561</b>	<b>\$1,948</b>	<b>\$613</b>	<b>24%</b>

# Duluth Cooling Cost Comparison

## Job Information

Job Title:

Job Type:

Notes:

## Location Information

Region:

Location:

City:

## Building Information

Building Type:

Unit Peak Clg Load:  Tons

## Energy Prices

Input Data:

Electric Price (Avg):  \$/kWh

Gas Price (Avg):  \$/MCF

## Equipment Information

	Baseline	Proposed
Unit Description:	<input type="text" value="Unit 1"/>	<input type="text" value="Unit 2"/>
Equipment Type:	<input type="text" value="Cooling with Gas Heat"/>	<input type="text" value="Cooling with Gas Heat"/>
Model:	<input type="text" value="48TC"/>	<input type="text" value="48TC"/>
Size:	<input type="text" value="ED12 (Medium Heat)"/>	<input type="text" value="ED12 (Medium Heat)"/>
Refrigerant:	<input type="text" value="R-410a"/>	<input type="text" value="R-410a"/>
Age (yrs):	<input type="text" value="0"/> Years	<input type="text"/>
Nominal Cooling Capacity:	<input type="text" value="10.0"/> Tons	<input type="text" value="10.0"/> Tons
AHRI Cooling Rating:	<input type="text" value="11.10"/> <input type="text" value="EER"/>	<input type="text" value="11.10"/> <input type="text" value="EER"/>
Capacity Control:	<input type="text" value="2-Stage"/>	<input type="text" value="2-Stage"/>
Heating Capacity:	<input type="text" value="184.0"/> MBH	<input type="text" value="184.0"/> MBH
AHRI Heating Rating:	<input type="text"/>	<input type="text"/>
Heating Efficiency:	<input type="text" value="82"/> %	<input type="text" value="82"/> %
Indoor Fan Power:	<input type="text" value="Med. Static, 3Pt"/> <input type="text" value="3.70"/> BHP	<input type="text" value="Med. Static, 3Pt"/> <input type="text" value="3.70"/> BHP
Indoor Fan Control:	<input type="text" value="1-Speed"/>	<input type="text" value="2-Speed"/>
Economizer:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Energy Recovery:	<input type="checkbox"/>	<input type="checkbox"/>
DCV (CO2) Control:	<input type="checkbox"/>	<input type="checkbox"/>
Purchase Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Installation Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Ann. Maint. + Repair (\$/yr):	<input type="text" value="0"/>	<input type="text" value="0"/>
Downtime Loss (\$/yr.):	<input type="text" value="0"/>	<input type="text"/>

# Duluth Cooling Cost Comparison

**Job Title:** Duluth Example

**Job Type:** Replacement

**Notes:**

## Key Results

<b>Energy Cost Savings over 5 years:</b>	<b>\$2,220</b>
<b>Maintenance, Repair, Downtime, Refrig. Savings over 5 years:</b>	<b>\$0</b>
<b>Total Savings over 5 years:</b>	<b>\$2,220</b>
<b>Annual Energy Cost Savings:</b>	<b>\$444 (19%)</b>

## Energy Cost Savings

<b>Criteria</b>	<b>Unit 1 (\$)</b>	<b>Unit 2 (\$)</b>	<b>Energy Savings (\$)</b>	<b>Percent Savings (%)</b>
Indoor Fan	\$1,384	\$834	\$549	40%
Cooling Electric	\$121	\$128	-\$7	na
Heating Electric	na	na	na	na
Heating Natural Gas	\$863	\$962	-\$98	na
<b>Annual Energy Costs</b>	<b>\$2,368</b>	<b>\$1,924</b>	<b>\$444</b>	<b>19%</b>

# South Bend Cooling Cost Comparison

**Job Information**

Job Title:

Job Type:

Notes:

**Location Information**

Region:

Location:

City:

**Building Information**

Building Type:

Unit Peak Clg Load:  Tons

**Energy Prices**

Input Data:

Electric Price (Avg):  \$/kWh

Gas Price (Avg):  \$/MCF

**Equipment Information**

	Baseline	Proposed
Unit Description:	<input type="text" value="Unit 1"/>	<input type="text" value="Unit 2"/>
Equipment Type:	<input type="text" value="Cooling with Gas Heat"/>	<input type="text" value="Cooling with Gas Heat"/>
Model:	<input type="text" value="48TC"/>	<input type="text" value="48TC"/>
Size:	<input type="text" value="ED12 (Medium Heat)"/>	<input type="text" value="ED12 (Medium Heat)"/>
Refrigerant:	<input type="text" value="R-410a"/>	<input type="text" value="R-410a"/>
Age (yrs):	<input type="text" value="0"/> Years	<input type="text"/>
Nominal Cooling Capacity:	<input type="text" value="10.0"/> Tons	<input type="text" value="10.0"/> Tons
AHRI Cooling Rating:	<input type="text" value="11.10"/> <input type="text" value="EER"/>	<input type="text" value="11.10"/> <input type="text" value="EER"/>
Capacity Control:	<input type="text" value="2-Stage"/>	<input type="text" value="2-Stage"/>
Heating Capacity:	<input type="text" value="184.0"/> MBH	<input type="text" value="184.0"/> MBH
AHRI Heating Rating:	<input type="text"/> <input type="text" value="COP"/>	<input type="text"/> <input type="text" value="COP"/>
Heating Efficiency:	<input type="text" value="82"/> %	<input type="text" value="82"/> %
Indoor Fan Power:	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP	<input type="text" value="Med. Static, 3Pr"/> <input type="text" value="3.70"/> BHP
Indoor Fan Control:	<input type="text" value="1-Speed"/>	<input type="text" value="2-Speed"/>
Economizer:	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Energy Recovery:	<input type="checkbox"/>	<input type="checkbox"/>
DCV (CO2) Control:	<input type="checkbox"/>	<input type="checkbox"/>
Purchase Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Installation Cost (\$):	<input type="text" value="0"/>	<input type="text" value="0"/>
Ann. Maint. + Repair (\$/yr):	<input type="text" value="0"/>	<input type="text" value="0"/>
Downtime Loss (\$/yr.)	<input type="text" value="0"/>	<input type="text"/>

# South Bend Cooling Cost Comparison

Job Title: Indiana Example

Job Type: Replacement

Notes:

## Key Results



Energy Cost Savings over 5 years:	\$2,888
Maintenance, Repair, Downtime, Refrig. Savings over 5 years:	\$0
Total Savings over 5 years:	\$2,888
Annual Energy Cost Savings:	\$578 (28%)

## Energy Cost Savings

Criteria	Unit 1 (\$)	Unit 2 (\$)	Energy Savings (\$)	Percent Savings (%)
Indoor Fan	\$1,397	\$757	\$640	46%
Cooling Electric	\$304	\$296	\$8	3%
Heating Electric	na	na	na	na
Heating Natural Gas	\$326	\$397	\$-70	na
Annual Energy Costs	\$2,027	\$1,449	\$578	28%

# High Efficiency RTU w/ SAV

## Product Design Strategy




### Benefits

- Saves Energy
- Greater Comfort
- Better Match, Typical Building Profiles
- Greater IEER's
- Simple Design

# SAV™ SYSTEM DESIGN

## Key components (DDC Controls)


Unit Internal Components



# SAV™ SYSTEM DESIGN

## Key components (electro-mechanical unit)

### Unit Internal Components



Designed factory logic automatically adjusts fan speed

VFD is factory programmed for 67% and 100%



# Compatible Economizer for SAV

**New W7220 Economizer controller provides the needed 2-speed operation plus new set up and diagnostic capabilities.**


- Large 2-line LCD interface screen for setup, configuration and troubleshooting
- On board fault detection and diagnostics
- Automatic recognized sensor detection
- Incorporates multiple economizer damper set point capabilities for use with multi speed indoor fan motor system
- Demand control ventilation capability



# ECONOMIZER IMPACT

## Why TWO minimum economizer positions?

Blower with adaptive economizer operation:  
Blower Speed (67%) Blower with adaptive economizer operation:  
2680 CFM SA (67%) 800 CFM Original position (20% SA) 520 CFM



Entering Assumptions:

10 ton 2-speed fan unit with 400 CFM/ton (4000 CFM SA)

800 CFM ventilation requirement (20% SA)

# Example Rebates for VFDs

- Minnesota Power
  - \$40-60 per HP
- Focus on Energy in Wisconsin
  - \$50 per HP
- Minnesota Xcel
  - \$400+ ... see side >>>
- ComEd Electric in Illinois
  - \$60 per HP
  - Or as part of new ARC
  - \$92 per HP (DCEO for public bldgs)
- Energizing Indiana
  - \$40 per HP
- Efficiency United in Michigan
  - \$60 per HP


Motor HP	Prescriptive Rebate Levels
1	\$400
1.5	\$400
2	\$400
3	\$400
5	\$600
7.5	\$750
10	\$1,000
15	\$1,250
20	\$1,600
25	\$2,000
30	\$2,400
40	\$3,000
50	\$3,500
60	\$4,000
75	\$5,000
100	\$6,000
125	\$7,000
150	\$7,000
200	\$8,000
Larger than 200	Requires custom evaluation and preapproval.

Please read all rules and qualifications for each incentive.

# Choices for SAV

## New RTUs

- Carrier/Bryant
- Daikin/McQuay
- Lennox
- Trane




## Retro-fit Kits

- CATALYST
- Enerfit
- Digi-RTU
- Honeywell ???



# Carrier WeatherExpert vs McQuay Rebel™ - Efficiency

## Gas Heat / Electric Cooling Models



Carrier from product catalogs (April 2012 and March 2013)  
McQuay from catalog 256-6 (March 2013) and website (Jan 2014)  
Lennox data not published with SAV included in IEER  
Trane data not available

# Items to Consider When Choosing

- Is the RTU or Retrofit kit available with adaptive integrated economizer control (aka dual minimum setpoints) to ensure minimum ventilation rate is not impacted?
- Is knowledge of a specific brand of DDC controls required?
- Is the SAV option available on their high-end and entry level units or must you get all the bells and whistles just to get SAV?
- Are other advanced options, such as ERV or dehumidification systems available on the same RTU?
- Is VFD field programming required or is it factory set?

# The CATALYST is a complete retrofit solution for existing RTUs



**tw** transformativewave  
**catalyst**

- Adds 4-5 new sensors and a variable frequency drive.
- Provides CO<sub>2</sub>-based demand control ventilation
- Advanced economization control sequence.
- Variable speed supply fan control
- Remote web-based communications via smart phone, tablet, or browser.

# The CATALYST is a complete retrofit solution for existing RTUs



**tw** transformativewave  
**catalyst**

- Proven track record of reducing overall energy use by 25%-50%
- Maintains comfort & IAQ
- Automatic air flow adjustments to protect equipment.
- Solves Power Exhaust problem
- Upgrade option replaces thermostats with Tridium BMS control via the web.
- Demand-Response capable






# Constant Volume RTUs

## The Most Potential:

- Units 5-tons and up
- 1 hp fan motors and up
- All brands and ages
- Fan-only = OK



# The CATALYST is delivered as a complete retrofit “kit”



Pre-engineered, pre-programmed, and can be installed in only a few hours.  
Produces a repeatable and scalable process with predictable results.



# Energy Savings Strategies

**Integrated Economizer with Differential  
Changeover Control**














**Variable Speed Fan Control to Match the  
Needs of the Space Served**

**Elimination of Over-Ventilation via  
Demand Control Ventilation (DCV)**

**Remediation of Service and Operational Issues**

# ECONOMIZER PERFORMANCE VERIFICATION

## Unit03 Health Status

Drive Communication	
Drive Fault	
Fan Run	
Fan Belt	
Heating Fail	
Cooling Fail	
Damper Fail	
Space Sensor	
Supply Sensor	
Return Sensor	
OSA Sensor	
CO2 Sensor	
Service Off	

Fault detection monitors for numerous conditions including economizer damper failure and sensor failures.

# CATALYST Service Switch



- A multi-position selectable switch for service personnel use. This will enable techs to operate the system in any mode of operation for maintenance purposes.
- The use of the service switch will suppress data collection by the eIQ Platform to avoid negative impact on fault detection and analytics.

Empowers contractors to easily perform preventative maintenance and verify economizer functions without undermining the CATALYST installation.

# Department of Energy

New study by PNNL shows CATALYST saved an average energy savings of 57% on 66 RTUs across 4 US climate zones.



U.S. DEPARTMENT OF  
**ENERGY**



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

# Department of Energy

The DOE chose to work with Transformative Wave's CATALYST based on “its features & product maturity”



U.S. DEPARTMENT OF  
**ENERGY**



**Pacific Northwest**  
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

# RTU EFFICIENCY STRATEGY



optimize



upgrade



perpetuate



Performance Monitoring

Visual Fault Reporting

Perpetual Trending

Icon-based Status Indications

Fault Prioritization

Demand Management

Unit sub-metering

Remote Troubleshooting

Outlier Identification

Predictive Maintenance

Life Cycle Extension

Advanced Fault Detection and Diagnostic Routines

Portfolio Energy & Performance Management

HVAC Asset Management Tools

e



energy intelligence platform

Powered by **niagara** AX FRAMEWORK

Select Report

**AC\_13** CATALYST Communication Status

Supply Air Alert: Normal    Supply Air Alarm: Normal

Space Temperature	72.3 °F
Occupancy Schedule	Occupied
Occupied Heating Setpoint	68.0 °F
Occupied Cooling Setpoint	72.0 °F
Unoccupied Heating Setpoint	62.0 °F
Unoccupied Cooling Setpoint	80.0 °F
Heating Load	0 %
Cooling Load	12 %
CO2Sensor	525.0 ppm
CO2Setpoint	1000 ppm
Outside Air Damper	100 %
Return Air Temperature	73.2 °F
Supply Air Temperature	61.9 °F
Mixed Air Temperature	62.9 °F
Outside Air Temperature	51.6 °F

Mixed Air 62.9 °F

Supply Air 61.9 °F

Return Air 73.2 °F

Outside Air 51.6 °F


Fan Speed 40 %  
Fan Power 0.25 kW

OSA 100 %

- ESH Mode
- Occupied
- Fan On/Off
- Vent
- Cool Mode
- EconMode
- Compressor1
- Compressor2
- Heat Mode
- Heat1
- Heat2
- Unit Details

**tuw** transformativewave **catalyst**

# ESTIMATED COST SAVING RANGES FOR U.S. COMMERCIAL BUILDING HVACs WITH EFFICIENCY CONTROLS



SOURCE: Figure ES 3, "Energy Savings and Economics of Advanced Control Strategies for Packaged Air-Conditioning Units with Gas Heat," Pacific Northwest National Laboratory, December 2011.

# Case Study



**Install Date:** March 2010

**Location Type:** Retail - Showroom

**Project Details:** HVAC Equipment: (40) Gas/Electric units, Average Size 12.5 Tons  
Projected Savings: 327,000 kWh/year

### Savings Summary

Projected Payback: 1.8 Years  
ROI: 56%  
HVAC Fan Energy: 69% Savings in Fan Energy Usage  
Utility Bill Analysis: 9% Reduction in Total Building Energy Use



**Unit06**


Thermostat Commands	
Fan Call	Yes
Cool Call 1	Off
Cool Call 2	Off
Heat Call 1	Off
Heat Call 2	Off
Occupied	Occupied
CO2Sensor	558.3
CO2Setpoint	800
Outside Air Damper	32 %
Return Air Temperature	69.3 °F
Supply Air Temperature	67.1 °F
Outside Air Temperature	53.4 °F



Home Performance History Alarms Schedules Email Admin Logoff

Store Summaries  
Chandler AZ  
Scottsdale AZ

Home Setpoints Alarms Schedules

 76.0 °F  
Fair

Chandler AZ  
2955 West Ray Road

Unit Name	Serves	Comm Mode	Health	Occ	Fan Call	Comfort Status	Space Temp	Actual Heat	Actual S/P	Fan Cool S/P	Fan Status	Fan Speed	Fan Power	Cooling 1	Cooling 2	Heating 1	Heating 2	Supply	Return	OSA or Clg	CO2	OSA Volume
Unit01	Sales East						73.9 °F	69 °F	73 °F		75 %	4.70 kW					60.2 °F	75.4 °F	58.9 °F	433 ppm	-	
Unit02	Sales West						71.5 °F	68 °F	73 °F		75 %	5.20 kW					75.1 °F	74.6 °F	74.3 °F	431 ppm	-	
Unit03	Receiving						73.6 °F	69 °F	73 °F		75 %	0.99 kW					60.6 °F	76.2 °F	92.6 °F	417 ppm	-	
Unit04	Kitchen Prep						73.6 °F	69 °F	73 °F		100 %	1.50 kW					69.2 °F	73.3 °F	50.0 °F	451 ppm	-	
Unit05	Check Stand						71.2 °F	69 °F	73 °F		100 %	1.53 kW					63.3 °F	74.1 °F	46.9 °F	434 ppm	-	
Unit06	Vestibule						73.6 °F	68 °F	73 °F		90 %	0.89 kW					64.9 °F	74.1 °F	82.2 °F	407 ppm	-	

**Site Data**

OSA Humidity  
16.8 %RH

OSA Dewpoint  
41.1 °F

Space Static  
0.00 in/wc

Unit Name	Serves	Space Humidity	Space Humidity Setpoint	Dehumidification Cool	Dehumidification Reheat	Dehumidification Su	Dehumidification Fan Speed Minimum	Space Dewpoint
Unit01	Sales East	33.5 %RH	45.0 %			50.0 °F	75.0 %	43.5 °F
Unit02	Sales West	46.2 %RH	45.0 %			50.0 °F	75.0 %	50.1 °F
Unit03	Receiving	-	-	-	-	-	-	-
Unit04	Kitchen Prep	47.6 %RH	45.0 %			50.0 °F	75.0 %	51.9 °F
Unit05	Check Stand	46.1 %RH	45.0 %			50.0 °F	75.0 %	49.5 °F
Unit06	Vestibule	-	-	-	-	-	-	-

This screenshot from the eIQ summary view of the store shows the various aspects of the eIQ web interface that can be customized for each client. Humidity is controlled based on dew point. Lower fan speed allows for more effective dehumidification by the HVAC system.



72.0 °F  
Clear

Scottsdale  
7111 E. Mayo Blvd.



Unit Name	Serves	Comm Mode	Health	Occ	Fan Call	Comfort Status	Space Temp	Actual Heat S/P	Actual Cool S/P	Fan Status	Fan Speed	Fan Power	Cooling 1	Cooling 2	Heating 1	Heating 2	Supply	Return	OSA	CO2	OSA Volume
Unit01	Sales Seafood	📶	🔄	⚠️	☀️	🟢	71.6 °F	70 °F	73 °F	🟢	40 %	0.34 kW	🟡	🟡	🟡	🟡	80.3 °F	77.5 °F	87.9 °F	446 ppm	-
Unit02	Main Sales Cntr	📶	🔄	⚠️	☀️	🟢	72.3 °F	70 °F	73 °F	🟢	40 %	0.33 kW	🟡	🟡	🟡	🟡	80.7 °F	77.8 °F	88.7 °F	450 ppm	-
Unit03	Sales Tapas	📶	🔄	⚠️	☀️	🟢	72.8 °F	70 °F	73 °F	🟢	40 %	0.36 kW	🟡	🟡	🟡	🟡	79.7 °F	76.7 °F	88.0 °F	473 ppm	-
Unit04	Loading Dock	📶	🔄	+	☀️	🟢	70.3 °F	68 °F	71 °F	🟢	90 %	1.80 kW	🟢	🟢	🟡	🟡	53.0 °F	72.1 °F	84.2 °F	412 ppm	-
Unit05	Food Prep	📶	🔄	+	☀️	🟢	71.0 °F	68 °F	71 °F	🟢	40 %	0.13 kW	🟡	🟡	🟡	🟡	82.7 °F	77.8 °F	82.7 °F	392 ppm	-
Unit06	Checkstands	📶	🔄	+	☀️	🟢	70.6 °F	68 °F	73 °F	🟢	40 %	0.14 kW	🟡	🟡	🟡	🟡	82.8 °F	78.1 °F	80.3 °F	442 ppm	-
Unit07	Bakery	📶	🔄	+	☀️	🟢	71.5 °F	68 °F	71 °F	🟢	40 %	0.14 kW	🟡	🟡	🟡	🟡	81.4 °F	77.6 °F	80.6 °F	472 ppm	-
Unit08	Vestibule	📶	🔄	⚠️	☀️	🟢	74.0 °F	68 °F	71 °F	🟢	90 %	0.84 kW	🟢	🟢	🟡	🟡	45.2 °F	74.0 °F	82.4 °F	-	-
Unit09	Produce	📶	🔄	+	☀️	🟢	72.3 °F	68 °F	71 °F	🟢	90 %	0.46 kW	🟢	🟢	🟡	🟡	46.3 °F	76.8 °F	47.6 °F	443 ppm	-

Site Data	Space Humidity	Space Humidity Setpoint	Dehumidification		Dehumidification Su	Dehumidification Fan		Space Dewpoint
			Cool	Reheat		Speed	Setpoint	
OSA Humidity 20.5 %RH	Unit01 31.3 %RH	50.0 %	🟡	🟡		80.0 %	39.7 °F	
	Unit02 28.8 %RH	50.0 %	🟡	🟡	-	80.0 %	38.1 °F	
	Unit03 35.7 %RH	50.0 %	🟡	🟡	-	80.0 %	44.7 °F	
OSA Dewpoint 39.4 °F	Unit04 -	-	-	-	-	-	-	
	Unit05 -	-	-	-	-	-	-	
	Unit06 34.4 %RH	50.0 %	🟡	🟡	55.0 °F	75.0 %	41.3 °F	
	Unit07 34.9 %RH	50.0 %	🟡	🟡	55.0 °F	75.0 %	42.5 °F	
Space Static 0.02 in/wc	Unit08 -	-	-	-	-	-	-	
	Unit09 32.7 %RH	50.0 %	🟡	🟡	55.0 °F	75.0 %	41.4 °F	

Fault Detection has identified fan belts slipping on Units 1-3. Humidity has historically been an issue at this store during the “monsoon” season. The CATALYST supermarket control sequence has enabled us to get the store humidity issues under control.



**tw** transformative**wave**  
**catalyst**

The CATALYST has a four-year track record of proven results.

The product is mature and fully commercialized with almost 1,000 installations.