

# Saving Energy in Existing Multifamily Buildings

Duluth Energy Design Conference  
February 21<sup>st</sup>, 2017

Dan May  
Center for Energy and Environment



In accordance with the Department of Labor and Industry's statute 326.0981, Subd. 11,

“This educational offering is recognized by the Minnesota Department of Labor and Industry as satisfying **1.5 hours** of credit toward **Building Officials and Residential Contractors code/energy** continuing education requirements.”

For additional continuing education approvals, please see your credit tracking card.



## Topics

- Who is CEE
- Energy use and building performance
- Retrofit highlights
  - Energy impact
  - Marketability
  - Ensuring success: I, O & M best practices

## About me



### **Dan May, Multifamily Project Coordinator**

- 8+ years in residential building efficiency & building inspections
- BPI certified Building Analyst
- Coordinator for Multifamily Energy Savings program for MN Energy Resources
- Perform other multifamily energy efficiency projects and research
- B.S. in Residential Building Science Technology, B.A.S. in Construction Management: U of M-Twin Cities




## Who is CEE

The Center for Energy and Environment (CEE) is a nonprofit organization that promotes energy efficiency to strengthen the economy while improving the environment

We conduct research and develop programs so that:

- Businesses operate more efficiently and profitably;
- Government agencies and nonprofits spend less on facilities and functions;
- Utilities achieve their energy-efficiency goals at least-cost; and
- Households save money and improve comfort.

# 35 Years of Clean Energy Accomplishments



## CEE multifamily experience

- Facility assessments of over 2,000 buildings in Minnesota
- Completed over 20 research projects



## Current multifamily research projects



- Condensing boiler optimization
- Multifamily ventilation optimization
- Assessment of through-wall condensing furnace/AC packages
- Multifamily aerosol envelope air sealing
- Indoor pool optimization

*All funded through the MN Department of Commerce's Conservation Applied Research and Development grant program.*






## Current multifamily energy efficiency programs

- Energy Star and Enterprise Green Communities multifamily 3<sup>rd</sup> party verifier
- One Stop Efficiency Shop lighting program with Xcel Energy
- Multifamily Energy Savings program with MN Energy Resources

# Energy use and building performance




# Water and space heating costs dominate



SOURCE: Minnesota Multifamily Rental Characterization Study, Energy Center of Wisconsin and Franklin Energy, 2013; sampled 120 buildings in MN (78 in Twin Cities, 66 Greater MN)


# ...And yet they are a small piece of the expense pie

Average  
MN Multifamily  
operating  
expenses



Source: 2013 MN  
Multi Housing  
Association  
Expense survey.  
388 multifamily  
properties  
surveyed

## High energy users in (almost) every age category






## Drivers of building energy use

- Efficiency of equipment (Boilers, water heaters, lighting, appliances, ventilation equipment, etc)
- Windows, insulation and envelope details
- Building maintenance protocols
- Staff practices & building operation
- Weather
- Location of building
- Resident habits

# Building energy use affects building performance





# Energy efficiency should improve building performance

## A good investment:

- Has aggressive energy paybacks
- Lowers O & M costs
- Improves building comfort
- Makes things easier for staff
- Is “tried and true”
- Is easy to implement
- Improves equip. durability



# Marketable energy efficiency strategies for MN multifamily






# Laundry list items

- Low flow water fixtures
  - Showerheads, aerators, toilets
- Lighting
  - LED replacement, occupancy sensors
- High efficiency washing machines
- Programmable thermostats for common spaces
- Pipe insulation
- Attic insulation and air sealing
- Water heater setting (120 degrees F)

# High-efficiency fixtures

**Low-flow showerhead, 1.5 gpm**  
Standard, 2.5 gpm




**Low-flow aerator, 0.5-1.0 gpm**  
Standard, 2.2 gpm



Payback on investment:  
1-3 years

# Curbing leaks

- Encourage reporting of faucet drips and running toilets





## • Get rid of *all* incandescent bulbs

- CFL or LED replacements are both good options
- \$5+ / year / bulb energy savings when you replace an incandescent
- LED last 50,000 hours rather than 8-10,000 for CFL or 1,200 for incandescent
  - Maintenance costs saved on longer bulb life

# Lineal fluorescent corridor or garage lighting

- T12 lamps to T8
- Magnetic ballasts to electronic
- Look for rebates

“Change them now”

Payback:  
2-3 years



# Other lighting upgrades: Occupancy sensors or timers

- Community rooms
- Computer rooms
- Laundry rooms
- Stairwells
- Garages (partial)
- Hallway (partial)



# ●●● Pipe insulation

*Insulate all accessible pipes*

**Heating pipes**

Payback  $\approx$  3.5 years

**Hot water pipes**

Payback  $\approx$  3 years






# Air-sealing: Stop attic air leaks

*Air sealing is sealing holes that leak heated air in a building shell with a material that stops air (caulk or foam)*

- Attic air leaks can cause ice dams on pitched roofs
- Pre-WWII buildings have most air leakage



# Garage Ventilation: CO monitoring controls and garage thermostat 50°F max

- Monitors Carbon Monoxide levels and operates ventilation system only when CO levels are high
- Garage thermostat at 50°F maximum





## • Good opportunities for energy savings – *beyond “the laundry list”*

- Optimizing existing boilers
- Building ventilation modifications
- Demand-based hot water recirculation loop controls
- Aerosol envelope air sealing



## Acknowledgements

Projects discussed are supported in part by a grant from the Minnesota Department of Commerce, Division of Energy Resources through a Conservation Applied Research and Development (CARD) program



# Optimizing Boiler Controls





## **Control boilers for optimal efficiency**

- Condensing & non-condensing boilers
- Optimized outdoor reset
- Finding the lowest max output temp for the building
- Sequencing and staging for optimal efficiency

# Boiler outdoor reset and warm weather shutdown controls



10-15%  
savings on  
heating  
costs

Reduced  
over-heating

Longer  
boiler cycles


• Control the boiler so it doesn't exceed demand







# Outdoor reset lowers boiler water temperature


As outdoor temps get warmer, the building heating load gets smaller and the boiler water temperature can be lowered.



# There's something wrong with these pictures



15 minutes could save you 15% on your heating bill



# Boiler Room Log: Note the boiler temp vs. outside air temp

Initials	Date	Pressure	Boiler Temp	Outside Air Temp	Comments
Am	1 <sup>st</sup> 11/16	17 lb	182	65°	Fixed up heat - B
Am	2 <sup>nd</sup> 11/16	17	180	74°	DHW only
Am	3 <sup>rd</sup> 11/16	16/17	180	70°	DHW
Am	4 <sup>th</sup> 11/16	17	182	69°	DHW
Am	5 <sup>th</sup> 11/16	17	180	65°	DHW
Am	6 <sup>th</sup> 11/16	17	180	66°	DHW
Am	7 <sup>th</sup> 11/16	17	182	64°	DHW
Am	8 <sup>th</sup> 11/16	18	180	64	DHW
Am Saturday	9 <sup>th</sup> 11/16	17	180	60°	DHW
Am	10 <sup>th</sup> 11/16	17	180	60°	Heat running now - A
Am	11 <sup>th</sup> 11/16	18	182	60°	All Normal
Am	12 <sup>th</sup> 11/16	17	180	62°	ok
Am	13 <sup>th</sup> 11/16	17	182	60	ok
Am	14 <sup>th</sup> 11/16	17	180	51°	ok
Am	15 <sup>th</sup> 11/16	17	182	51°	ok
Am	16 <sup>th</sup> 11/16	17	179	57°	ok
Am	17 <sup>th</sup> 11/16	17	182	49°	ok
Am	18 <sup>th</sup> 11/16	18	180	50°	ok
Am	19 <sup>th</sup> 11/16	17	180	39°	ok
Am	20 <sup>th</sup> 11/16	17	182	45°	ok
Am	21 <sup>st</sup> 11/16	17	180	39°	ok
Am	22 <sup>nd</sup> 11/16	17	<del>180</del> 180	38°	ok
Am	23 <sup>rd</sup> 11/16	16/17	182	32°	Added 2 lb B
Am	24 <sup>th</sup> 11/16	17	180	32°	ok
Am	25 <sup>th</sup> 11/16	17	180	30°	Replaced Coupler B
Am	26 <sup>th</sup> 11/16	17	182	40°	ok
Am	27 <sup>th</sup> 11/16	17	180	38°	ok
Am	28 <sup>th</sup> 11/16	18	182	38°	ok
Am	29 <sup>th</sup> 11/16	17	180	29°	ok
Am	30 <sup>th</sup> 11/16	17	182	27°	ok
Am	31 <sup>st</sup> 11/16	17	180	30°	ok


## Outdoor reset adjustment

14 unit building:  
9.5% space heating savings (no cost)  
Reduced building over-heating




# At replacement: Identify boiler control limitations

- This boiler control's non-adjustable minimum outside temp of 0°F is not ideal for MN




# Understanding reset control settings

- Outdoor design
- Boiler indoor/indoor design/Room design
- Boiler design
- Boiler max
- Boiler min
- WWSD/Shutdown



# Adjusting outdoor reset—dollars and cents





# Make it easy!!



**Tekmar 254**  
settings for  
Reset/Cutout  
control

## Multifamily Boiler Outdoor Reset / Cutout Control Operating Guidelines©

The tables and charts that follow are CEE's recommended operating guidelines for your building's boiler outdoor air reset and cutout control. Recommended initial settings are based on actual field experience with typical multifamily buildings. However, your specific building may require fine-tuning of the controller settings, as specified in the fine-tuning adjustments instructions later in this document. The final controller settings are expected to lie within the adjustment ranges noted in the attached tables and charts.

### Your basic process is as follows:

- 1- Make adjustments to your reset and cutout control settings according to our "Recommended Initial Settings" instructions
- 2- Observe building operation
- 3- Utilize Zone-Specific Issues Checklist (below) to address any zone-specific problems
- 4- Make adjustments to the reset controller utilizing the "Fine Tuning Adjustments"
- 5- Record all adjustments or over heating/under heating complaints and subsequent control adjustments on the "Control Settings Log"

### Zone-Specific Issues Checklist

Zone-specific problems must be identified and corrected before fine-tuning the boiler control settings in response to a tenant complaint or observed over/under heating. Below is a list of common zone-specific problems that should be checked when there is a problem.

- ☒ **Thermostat is inaccurate** (check against thermometer), is improperly located (next to heater or window), or doesn't provide proper signal (check for proper on-off of 24 volt output to zone valve as thermostat is adjusted above and below the current temperature).
- ☒ **Zone valve isn't operating or doesn't close tightly.** Feel pipe temperature in the zone compared to the main line temperature to see if hot water is circulated when it should and shouldn't be. Manually opening and closing the valve a few times often corrects problems with the valves being temporarily stuck open or closed. If a valve still doesn't respond properly to the thermostat, it may need to be replaced. (Note: Feel the pipe temperature at least one foot from the connection to the main line. Allow time for the pipe and radiators to warm or cool after hot water circulation is changed.)
- ☒ **Radiator blockage** by dust, curtains or furniture will reduce the heat output.
- ☒ **Unrealistic resident expectations** of apartment temperatures above 75°F may not be met. Similarly, it may not be possible to keep an apartment below 70°F because of heat coming from surrounding apartments. Measure and document apartment temperature with a thermometer when responding to heating complaints to address this potential issue with a resident.




# Optimizing condensing boilers




# Optimizing outdoor reset

Main Return vs OAT



# Achieving rated efficiency (>90% efficiency)




Little difference between boiler supply and return temperatures indicates potential for improvement

**1- Adjust reset temps as low as possible**


**2- VFD pump control optimizes heat transfer as zones open and close**

Day	Time	Outside Temp	System Temp	Main Supply Temp	Outlet Temp	Inlet Temp	Return Temp	Boiler Pressure Reading	Capacity %	Comments and Initials
1	4:16 <sup>pm</sup>	45°	120°	115			102	9/18		JAH Raised pressure to 18psi
2	7:15 <sup>am</sup>	17°	149°	142°			138°	14		JAH Raised Honeywell setting from 84-85 with Allen
3	12:03	33°	132°	122°			118°	9/18		JAH Raised reset pressure to 18psi
4	11:47	38°	120°	116°			108°	10/18		JAH Raised to 18 psi
5	1:50	38°	120°	115°			109°	11/18		JAH " "
6	7:10 <sup>am</sup>	32°	119°	116°			109°	10/17		K.R
7	11:59	46°	120°	114°			108°	6/19		JAH Raised pressure to 18psi Raised open to 90
8	8:33	32°	132	130°			121°	14/19		JAH Raised pressure to 18psi losing 2-7 gal/day
9	10:00	32°	130°	128°			120°	12/19		JAH " "
10	10:35	32°	133°	131°			119°	11/18		JAH Raised pressure to 18psi
11	12:12	32°	120°	118°			119°	11/18		JAH Raised pressure to 18psi

# Conventional boiler



# Condensing boiler







## Benefits


- 4-10% of gained efficiency
- Eliminate short-cycling
- Getting what you paid “extra” for



## The key:

### • Driving down return water temperature and managing excess air

- Maximize heat transfer at heating elements
- Send lower temp water out to the building
- Make sure boiler output matches demand
- Make sure your piping isn't dumping supply water into return






# How?

- **Considerations for an existing condensing system**
  - Proper excess air levels
  - Adjusting outdoor reset and sequencing/staging controls
  - Reducing maximum output temp
  - VFD pumping for increased heat transfer
- **OR Considerations at time of replacement**
  - Boiler room piping
  - Choosing a boiler with good on board reset and sequencing/staging controls

# Condensing boiler sensitivity to excess air

- Controlling excess air very important
  - Excess air reduces concentration of water vapor
  - Dewpoint decreases



# Oxygen levels in flue gas

Table 4: Recommended Combustion Levels

	Natural Gas All Models	Propane Solo 60/175/250	Propane Solo 399
O2 Min.	2.30%	2.70%	3.70%
O2 Max.	5.30%	4.70%	5.20%
CO2 Min.	8.80%	10.70%	10.00%
CO2 Max.	10.50%	12.00%	11.00%
CO Max.	100 ppm	100 ppm	100 ppm

Boiler 2


testo310  
V5.2 42813307/1  
Company \_\_\_\_\_  
Address \_\_\_\_\_  
Phone \_\_\_\_\_  
11/20/2014 12:57:52 pm  
Fuel Natural gas  
CO2max 11.7%  
→ 4.3% O2  
99ppm CO  
155.8°F Fluegas Temp  
88.5% EFF  
65.1°F Ambient CO  
--- inH2O Ambient Temp  
23.6% Draft  
--- inH2O Excess air  
H-9.24% Pressure  
126ppm CO2 Low-9.35  
Undiluted CO  
Smoke no. ---  
Smoke no. Ø ---  
HCT \_\_\_\_\_°F  
For questions call \_\_\_\_\_

Boiler 1

testo310  
V5.2 42813307/1  
Company \_\_\_\_\_  
Address \_\_\_\_\_  
Phone \_\_\_\_\_  
11/20/2014 12:28:07 pm  
Fuel Natural gas  
CO2max 11.7%  
→ 4.4% O2  
92ppm CO  
134.2°F Fluegas Temp  
89.0% EFF  
65.1°F Ambient CO  
--- inH2O Ambient Temp  
23.6% Draft  
--- inH2O Excess air  
H-9.24% Pressure  
115ppm CO2 low 9.41  
Undiluted CO  
Smoke no. ---  
Smoke no. Ø ---  
HCT \_\_\_\_\_°F  
For questions call \_\_\_\_\_

# Excess air can dictate boiler efficiency

*Measured as % Oxygen in flue gas*



# Boiler sequence and firing stage controls: matching output to load for best efficiency

Lower output firing stages have increased thermal efficiency




Image source: Lochinvar.com

# Lochinvar Knight boiler cascade strategies:





Image source: lochinvar.com




# Boiler room piping: address at replacement



Not ideal: Adjacent boilers warm return water

# Better piping





## **Summary: getting condensing boilers to condense!**

- Proper oxygen levels in flue gas contribute to optimal condensing conditions
- Maintaining aggressive control settings prolongs condensing capabilities
- VFD pump controls reduce pump speeds at part loads to optimize heat transfer
- Boiler room piping can dictate return water temps

# Optimizing ventilation systems





## Individual ventilation systems



- Ducted individually
- On/Off Switch in apartment
- Commonly under-ventilating (no energy savings)



# Central ventilation systems






## Multifamily central ventilation: What are the issues?


- Excessive ventilation flow rates
  - Electric use of motors
  - Cost of ventilating excessive heated or cooled air
- Lack of effective airflow distribution
  - Inlets clogging over time
  - Balancing dampers tampered with
- Difficulty measuring airflows

# Central Apartment Exhaust







# Exhaust systems draw air from apartments



**Bathroom**



**Kitchen & Bathroom**



**Two Bathrooms**

# ● Clogged or blocked inlets are a problem!

Flow balancing device behind the grill is often clogged or blocked



## **Solution:** **Fixed Orifice - “Sheet Metal With a Hole”**

- Less prone to clogging
- Tamper proof
- Least cost
- Sealed to ceiling
- Hole is sized for correct flow at targeted duct pressure



# Case study: Central exhaust retrofit in Minneapolis

- High utility bills
- Ventilation fan noise
- Repeated fan belt replacement
- Odor problems from blocked inlets



## • Retrofit: clean and unclog ducts



Remove balancing dampers and replace with fixed hole



# Replace fan with high-efficiency type and turn it down!

Air seal at curb below fan



# Results: Improved distribution

Pre – retrofit >

x05
4
63
56
147
161
171
30
50
26
15
100
190
NA

84

Post– retrofit >

x05
4
34
32
34
31
30
33
34
34
31
35
35
34
30
NA

33

Very High	> 45	67%
High	> 36	67%
Good	+/- 20%	17%
Low	< 24	17%
Very Low	< 15	17%

0
0
100%
0%
0%



# Savings Details

Whole building	
CFM savings	2,299 cfm
Gas savings (NG)	4,706 therms
Fan power savings	21,979 kWh
Cooling savings	5,539 kWh
Energy Cost savings*	<u>\$5,535</u>
Payback	6.1 yrs


Per unit annual savings	
Gas savings (NG)	58 therms
Electric savings	339 kWh
Energy Cost savings*	<u>\$67/unit</u>

\*Based upon \$0.65/therm and \$0.09/kWh

# Trash Chutes




# Typical Trash Chute Configuration



# Improving trash chute performance

- Keep trash room doors shut
- Weatherstrip and seal off trash rooms
- Adjust cap height



© 2014 Center for Energy and Environment

# Case study: Trash Chute retrofit in Minneapolis

- Reduced rooftop cap height to restrict stack flow
- Sheet metal housing at dumpster isolated trash chute from building air



## • Energy Savings, Reduced Odors

- Estimated \$1,500 annual heating savings
- Reduced odors in nearby lobby, management offices
- 1.3 year payback



 **Make sure the chute door is closed**





## Ventilation summary

- Over or under-ventilating systems have big impacts on building performance
- Reducing ventilation flow saves on operating costs
- Using a fixed orifice flow balancer will save costs and improve long-term performance
- Trash Chute modifications can improve odor issues and save energy





# For more ventilation information



## **Multifamily Ventilation Assessment and Retrofit Guide**

---

Conservation Applied Research & Development (CARD) Report

Prepared for: Minnesota Department of Commerce,  
Division of Energy Resources

Prepared by: Center for Energy and Environment



# Controlling hot water recirculation loops



# Hot water recirculation loops




Image source: HMG, Inc

# DHW energy losses




Image source: HMG, Inc. Multifamily Central Domestic Hot Water Distribution systems. 2013

## Rochester installation

- 3-story
- 39 unit building
- Built in 1955
- Failed water heaters
- Shower heads and faucet aerators installed along with building assessment



**25% total hot water savings**  
**10% DHW savings from Demand Controller**  
**Payback = 3.5 years**

## Enovative's Demand Controller

- Control stops pump when there is no building demand *or* the recirculation loop temp is above 100F
- Pump run time reduced from 24/7 to average 14 mins / day (ARIES Collaborative/Building America study in 2014)
- Turns pump on upon sensing hot water demand

Payback:  
2-4 years



# Aerosol envelope air sealing


## Concept:

- Pressurize apartment unit
- Spray air sealing fog
- Sealant particles build up on gaps as they exit the room

# • Multifamily compartmentalization

## *Creating an interior air barrier around each unit*

- Reduced stack effect
- Reduced noise transfer
- Reduced odor transfer/improved IAQ
- Increased comfort
- Increased energy efficiency







# Nuts and bolts

## PREP WORK

- Horizontal surfaces covered
- Windows, exterior doors covered
- Finished floor covered (ideal before flooring is installed)
- Door handles covered
- Plumbing fixtures covered
- Ceiling fans covered
- Radiators covered
- Sprinkler head openings covered
- Remove outlet/switch plates



## Preliminary results: Very air-tight

- Air tightness result: 114 to 25 CFM50 total unit leakage (8 units sealed)
- Averaged 0.45 ACH50
- 78% to 95% tighter than the new code requirement of 3.0 ACH50
- 12-13 times tighter than Energy Star requirement for multifamily



# Sealed penetrations





## Identifying the opportunity

### **IDEAL CANDIDATES**

- Moderate rehabs “floors and cabinets”
- New construction


### **NOT IDEAL**

- Where carpet is installed
- If occupied

## Air sealing at lower cost?

### Aerosol

- Prep
- Sealing process
- Simultaneous air leakage testing ensures results



### Manual air sealing

*i.e. caulking/foaming*

- Architectural specification
- Labor
- Air leakage test

**=> Uncertain results**



**Vs.**



# Marketable?

## **BENEFITS**


- Reduced noise transfer
- Reduced odor transfer
- Improved comfort
- Simultaneous air leakage testing ensures results
- Expedited process, labor savings potential

## **CONSIDERATIONS**

- Cost
- Not a solution for large air leak gaps
- Rehab or new construction only
- Balanced ventilation is crucial

# Condensing through-wall furnaces

- Through-wall furnaces becoming more popular in Multifamily buildings
- Recently, 4 out of 5 manufacturers of through-wall furnaces introduced condensing heating products
- Non-condensing: 80% AFUE, Condensing: Up to 95% AFUE





# Potential/Unresolved Issues: Existing Buildings

- How will condensate be handled?
  - Drain lines
  - Neutralization requirements
- Potential for icing issues at exterior grille during cold weather?
- Have any impact on occupant comfort?
- How do measured energy savings compare to initial savings estimates?

More of a concern for existing buildings





## Round-up

- Controlling boilers (both condensing and non-condensing) effectively is a low-cost way to save energy and improve occupant comfort
- Central ventilation systems that provide too much ventilation air can be modified for significant energy savings (plus improved ventilation performance)
- Demand-controlled recirculation loop controls on hot water systems are low costs controls that save energy without affecting performance
- Aerosol envelope air sealing may be the future's technique for meeting energy performance requirements

# Make sure to look for rebates!

## 2017 Business Lighting Rebate Application

**Lighting Equipment Rebate** Project Type:  New Construction  Retrofit

Existing/Base Equip.		New Equipment								Is This Space Air Conditioned?
Code (from Lighting Tables) <sup>1</sup>	Existing/ Base Quantity	Code (from Lighting Tables)	LED Bulb/Fixture Wattage (if applicable)	Fluor. Ballast Make (if applicable)	Fluor. Ballast Model (if applicable)	Fluor. Lamp Make (if applicable)	Fluor. Lamp Model (if applicable)	New Quantity	Annual Hours of Operation <sup>2</sup>	
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No
										<input type="checkbox"/> Yes <input type="checkbox"/> No

<sup>1</sup> Existing T12 fixtures must be working to be eligible for Retrofit Rebate.

**Occupancy Sensor/Photocell Rebate** Project Type:  New Construction  Retrofit

Controlled Fixtures				Occupancy Sensors/Photocells					Rebate per Sensor/ Photocell <sup>1</sup>	Total Rebate (Sensor Qty X Rebate per Sensor)
Code (from Lighting Tables)	Total LED Wattage (if applicable)	Low Wattage T5/T8 Lamps (if applicable)	Quantity Controlled by Sensors/ Photocells	Code (from Lighting Tables)	Sensor Quantity	% of time Lights Off <sup>2</sup>	Is This Space Air Conditioned?	Total Cost of Sensors/ Photocells		
		<input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input type="checkbox"/> No	\$	\$	
		<input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input type="checkbox"/> No	\$	\$	
		<input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input type="checkbox"/> No	\$	\$	
		<input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input type="checkbox"/> No	\$	\$	
		<input type="checkbox"/> Yes <input type="checkbox"/> No					<input type="checkbox"/> Yes <input type="checkbox"/> No	\$	\$	

Total Rebate Amount \$ \_\_\_\_\_

<sup>2</sup> Guidelines for % of Time Lights Off (TLO):

Sensor Type	TLO	Sensor Type	TLO	Sensor Type	TLO
Occupancy Sensor - Wall Mount	30%	Photocell - Continuous Dimming	43%	Photocell - On/Off	27%
Occupancy Sensor - Ceiling Mount	30%	Photocell - Multiple Step Dimming	35%	Integrated Occupancy Sensor	30%

## Commercial and industrial boiler heating system and components rebate application

### STEP 6 Equipment information

Please complete all information for the installed equipment for which you seek a rebate. Required information submitted as part of application to be eligible for a rebate. Please reference all rebate requirements prior to installation to ensure eligibility. Make a separate entry for each measure installed. If more space is needed, please photocopy this form and subm

### Rebate minimum efficiency requirements

Equipment or service	Rebate
<b>Hot water boiler system</b>	
85% to 89.9% AFUE (< 300,000 Btu/h input)	\$900 per MMBtu/h input
85% to 89.9% thermal efficiency (300,000 Btu/h or greater input)	
<b>Hot water boiler system</b>	
90% AFUE or higher (< 300,000 Btu/h input )	\$2,500 per MMBtu/h input
90% thermal efficiency or higher (300,000 Btu/h or greater input)	
<b>Steam boiler system</b>	
83% AFUE or higher (< 300,000 Btu/h input)	\$750 per MMBtu/h input
83% thermal efficiency or higher (300,000 Btu/h or greater input)	
<b>Other boiler heating system components and services</b>	
Continuous modulating burner (retrofit or upgrade only)*	25% of equipment cost
O2 trim control	25% of cost
Linkageless control	25% of cost
Electronic programmable setback thermostat for existing buildings**	50% of cost
Vent damper	50% of equipment cost
Boiler outdoor air reset control (retrofit or upgrade only)*	100% of equipment cost
Boiler cut-out control	100% of equipment cost


# Managers: Take advantage of this program!

- Free install of shower-heads and faucet aerators
- Building assessment
- Start-to-finish oversight of any chosen retrofits

It's  
**FREE**

Major cities served:

Cloquet  
Grand Rapids  
Bemidji  
Eagan  
Rochester  
Park Rapids  
Rosemount  
Hinckley  
+100 other MN cities



# More info CEE programs and research: [mncee.org](http://mncee.org)

## Minnesota Solar Pathways

This project undertakes stakeholder collaboration and technical analysis to support Minnesota's deployment of solar electricity.  
Dec 15, 2016 | Project



## CEE in 2016: Boots on the ground

As our past year shows, here at CEE we know that we can't get to *clean* energy without getting our hands *dirty*. It's all about rolling up our sleeves and digging in.

Dec 12, 2016 | Blog

## From the Blog




## Staff Spotlight: Russ Landry

In this series, learn how each CEE staffer contributes to reducing energy waste while improving the environment. This week, we profile senior mechanical engineer Russ Landry.

Feb 6, 2017 | Blog

## See All Posts Latest Tweets

 Ctr for Energy & Env  
@MnCEE

#Free energy wrkshp for  
#WorthingtonMN residents 2/18.  
Qual. for discounted energy visit-  
save \$ & #energy at home.  
[ow.ly/Vyn6308TpP](https://www.facebook.com/ow.ly/Vyn6308TpP)

THANK  
*you!*

Questions?

Dan May

[dmay@mncee.org](mailto:dmay@mncee.org)

612.244.2425

cee  
Center for Energy and Environment

